

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-0410:153 Page 1 of 1

CATEGORY: Annunciators

LISTEE: Hochiki America, 7051 Village Dr., Suite 100, Buena Park, CA 90621
*Contact: Bob Misiuk (714) 670-3251

DESIGN: Model HRAM-208 remote multiplex annunciator and HRTI-1 Remote trouble Indicator.
Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20-19 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as annunciator panel for use with listee's separately listed compatible Model HCP-200 Series fire alarm control unit (CSFM Listing No. 7165-0410:152).

XLF: 7120-1477:108

*Rev. 11-16-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 9, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager